



**NOTES**

- 1. NON-SHRINK GROUT SHALL BE IN A SUFFICIENT QUANTITY TO PROPERLY SEAL THE JOINT.
- 2. DIAMETER OF HOLE IN DRAINAGE STRUCTURE SHALL BE NO MORE THAN 3 IN. LARGER THAN THE PIPE O.D. UNLESS APPROVED BY ENGINEER.

DRAINAGE STRUCTURE - MAY BE MASONRY OR CONCRETE PER THE APPLICABLE COG STANDARDS

**CITY OF GREENSBORO**

**SOIL TIGHT CONNECTION FOR HDPE PIPE TO DRAINAGE STRUCTURES**

**STD. NO.**

**456**

**REV.**

**03-10**